Cadillac Meter

ACCURATE & RELIABLE ENERGY METERS

GENERAL INFORMATION

Cadillac® Magnetic Flow Meter CMAG Series



CENTRAL STATION STEAM CO.® 15615 SW 74TH AVE., STE #150 TIGARD, OR 97224 PHONE: 888-556-3913 FAX: 503-624-6131 @ WWW.CADILLACMETER.COM

THE LIQUID METER OF CHOICE

The Cadillac® magnetic flow meter is a rate and totalizing device, which is capable of measuring liquids of all types and consistency while providing an obstruction free flow path. Due to it's robust design, it is particularly suitable for pumped hot condensate as well as hot and chilled water. In any heating/cooling system the Cadillac® magnetic flow meter is the number one technology choice due to Cadillac®'s accuracy, linearity, reliability and rangeability.

Like many other flow meters, the Cadillac® magnetic flow meter is a velocity measuring device which computes flow by multiplying the effective cross sectional area of the flow meter with the detected fluid velocity. The meter has no moving parts and consists of a meter body with encapsulated coils, electrodes and an amplifier assembly. It detects velocity by measuring an induced voltage that is developed by moving the conductive fluid through a magnetic field. For a more detailed explanation, please review the "Principle of Operation" below.

THE NEW INDUSTRY STANDARD

Historically, liquid flows have been measured by mechanical flow meters. However, as with any mechanical system, the meters are subject to wear and tear, and require regular maintenance and calibration. Even though magnetic flow meters have been on the market for years, their high cost of manufacture have limited their use. Current manufacturing technology has made the Cadillac® magnetic flow meter a cost effective solution, especially in applications requiring analog (rate) or pulse (totalized) outputs.

APPLICATIONS


- Data Source for energy management system, DCS, district-wide systems.
- Energy-Customer Billing from accurately totalized flow measurements.
- Basis for internal cost distribution using campus-wide systems.
- Process monitoring from central control rooms.
- Cooling/heating load flows for Hydronic systems.
- Process flows of all liquid types (acids, caustics, abrasives, high suspended solids)

FEATURES

- ACCURACY: +/-0.25% or better of the reading for liquids. High accuracy allows significant improvement in both measurement and customer billing.
- **RANGEABILITY.:** Typically 300 to 1 turndown or better. With seasonal heating/cooling load variation, the need for a large turndown is essential. Cadillac® magnetic flow meters will accurately measure all load requirements with proper sizing.
- LONGEVITY: Mean time between failure (MTBF) of 75 years.
 With no moving parts and through simple robust design the meter has unmeasured life expectancy.
- **MODERN ELECTRONICS:** meeting the challenges of the next millennium Meters are equipped with electronics capable of registering locally, remotely or interfacing with an energy management system. Built to withstand the toughest conditions.

PRINCIPLE OF OPERATION

Faraday's law states that, when you move a conductor perpendicular through a magnetic field, a voltage will be induced proportional to the velocity of the conductor. A magnetic field is created by a set of coils which are encapsulated and rigidly retained in the meter flow tube and, when a conductive liquid moves through that magnetic field, a pair of electrodes measures the voltage induced by the movement of the liquid. The measurement is independent of conductivity changes in the liquid as long as it remains above the minimum threshold of 3.0



uS/cm.

The relationship between the liquid velocity and the induced voltage is expressed in a meter K-factor. The meter K-factor is unique to each and every meter and is documented during a NIST traceable flow test com-

pleted prior to shipment. With the K-factor established a highly accurate volumetric flow is calculated by multiplying the cross sectional area of the flow tube by the measured liquid velocity. This volumetric relationship can then be converted to various engineering units and the flow meter converter can then retransmit this information with a 4-20 mA current signal and / or conditioned pulse. An optional integral LCD Indicator/Totalizer is available to locally display and totalize in whatever engineering units


METER INSTALLATION Cadillac CMAG Piping Requirements

Installation requirements have been redefined with the Cadillac magnetic flow meter.

Employing coil and plate shaping techniques the Cadillac® meter provides a uniform magnetic flux shaping within the flow tube. This allows the meter to measure and sample uniformly the entire flow tube area.

In addition, the electronics provide high frequency DC square wave signal generation and flow signal sampling. When combined these two techniques eliminate all straight run flow profiling requirements, significantly decrease signal to noise ratio, and increase low flow accuracy.

In practice, this means the Cadillac magnetic flow meters may be installed next to elbows, tees, valves, etc. without any effect in meter accuracy or stability. (See Illustrations). This also allows the CMAG to be installed in gravity flow applications with a turndown of 300:1 @ +/-0.25% accuracy.



In comparison, the straight pipe run requirements for all other magnetic flow meters are as follows:

Downstream of the meter:

- ♦ Expander (2-5) diameters
- ♦ Tee (2-5) diameters
- ♦ Elbow (2-5) diameters
- ◊ Valves (2-10) diameters

• Upstream of the meter:

- ♦ Expander (10) diameters
- ♦ Tee (5) diameters
- ♦ Elbow (5) diameters
- \diamond Valves (10) diameters

Unlike other technologies such as the Cadillac® Vortex flow meter, magnetic flow meters do not have a low flow cutoff, essentially allowing the meter to read to zero. With such a wide flow range capability for the technology, most applications can be addressed with meters at full line size.


The Cadillac® magnetic flow meter has a 304 stainless steel body and is always sold with integral grounding rings installed. The primary reason for providing grounding rings is to contain the magnetic field within the meter body and to assure the liquid potential is grounded properly. As a consequence, the induced voltage is remarkably free of noise allowing the meter to reliably measure extremely low fluid velocities. The table below lists minimum and maximum 4-20 made output spans for each meter size, in GPM for liquids and lbs/hr for condensate.

| CMAG | Liquid Flow Range Table | | Condensate Flow Range Table | |
|---------------|-------------------------|--------------------|-----------------------------|--------------------|
| Meter Body | Minimum Volumetric | Maximum Volumetric | Minimum Condensate | Maximum Condensate |
| (inches) Size | (gal/min) Range | (gal/min) Range | (Ibs/hr) Range | (Ibs/hr) Range |
| 0.50" | 0.00 - 0.250 | 0.00 - 25.00 | 0.00 - 125.0 | 0.00 - 12,500 |
| 1.0" | 0.00 - 0.750 | 0.00 - 75.00 | 0.00 - 375.0 | 0.00 - 37,500 |
| 1.5" | 0.00 - 1.750 | 0.00 - 175.0 | 0.00 - 875.0 | 0.00 - 875,000 |
| 2.0" | 0.00 - 3.000 | 0.00 - 300.0 | 0.00 - 1,500 | 0.00 - 150,000 |
| 3.0" | 0.00 - 8.000 | 0.00 - 800.0 | 0.00 - 4,000 | 0.00 - 400,000 |
| 4.0" | 0.00 - 12.50 | 0.00 - 1,250 | 0.00 - 6,250 | 0.00 - 625,000 |
| 6.0" | 0.00 - 25.00 | 0.00 - 2,500 | 0.00 - 12,500 | 0.00 - 1,250,000 |
| 8.0" | 0.00 - 50.00 | 0.00 - 5,000 | 0.00 - 25,000 | 0.00 - 2,500,000 |
| 10.0" | 0.00 - 75.00 | 0.00 - 7,500 | 0.00 - 37,500 | 0.00 - 3,750,000 |

Low velocity "Turndown Accuracy" of the CMAG has allowed it to address applications, which were not possible for volumetric flow meters in the past. Below is the turndown accuracy for the CMAG:

♦ (+/- 0.25%) of rate at 300:1 turndown with 1.5 diameters of straight piping from meter centerline up/downstream.

- ♦ (+/- 0.50%) of rate from 300:1 to 400:1 turndown with 1.5 diameters of straight piping from meter centerline up/downstream.
- ♦ (+/- 1.00%) of rate from 400:1 to 500:1 turndown with 1.5 diameters of straight piping from meter centerline up/downstream.



CADILLAC® MAGNETIC FLOW METER GENERAL SPECIFICATIONS

- Meter will consist of a full-bore body with encapsulated and rigidly retained set of coils.
- Meter available with remote or integral electronics with indication and totalization.
- Meter operates at \pm 0.25% accuracy without flow profiling or piping straight run exceeding 1.5 diameters.
- Meter operates with minimum 300 to 1 turndown at stated operating accuracy.
- Meter available with pulse and analog (4-20 mA) outputs.
- Meter will provide instantaneous and totalized flow available at local indicator or remotely through outputs.
- Meter measures flow using Faraday's law (Induce voltage is directly proportional to the velocity of the conductive liquid)
- Meter K-factor is stable and not influenced by external piping or mounting orientation.
- Meter will have uniform magnetic field flux distribution eliminating piping straight run and flow profiling.
- Meter will measure fluids with conductivity greater than or equal to 3.0 uS/cm.
- Meter will be calibrated to/and provided with NIST calibration certificate.

CADILLAC® MAGMETER MODEL NUMBER STRUCTURE

